

CAN/CSA-Z317.2-01
***Special Requirements for
Heating, Ventilation,
and Air Conditioning
(HVAC) Systems in
Health Care Facilities***

*A National Standard of Canada
(approved February 2003)*

6.10.7 Duct Cleaning



CANADIAN STANDARDS
ASSOCIATION

Z317.13-03

***Infection Control during
Construction or Renovation
of Health Care Facilities***

7.4.3

Ductwork, diffusers, and all openings in the construction area shall be sealed ...

7.4.4

The contaminated areas shall be physically separated from uncontaminated areas ...

7.6.2

The work shall be performed by a qualified abatement contractor ...

7.6.7

If investigation determines that there's a risk of contamination ...



CANADIAN STANDARDS
ASSOCIATION